

Module 4: District Cooling

Combined heat and cold production, cold production technologies

SHaKE – Sharing Heat and Knowledge on Energy Communities

Erasmus+ KA220-HED Cooperation Partnerships in Higher Education

Developing institution: Universitat Jaume I de Castellón

Author: Dr. Adrián Mota-Babiloni and Ghad Alarnaot-Alarnaout

Date: May 2026

Version 1.1



SHaKE

Sharing Knowledge on Energy Communities



1. Combined heat and cold production

1.1. Heating and cooling principles

1.2. Simultaneous heating and cooling applications

1.3. Technology for heat pumps and chillers

1.4. Current technology of heat pumps for simultaneous heating and cooling production

1.5. Integration of heat pumps, configurations, and refrigerants

1.6. Waste and renewable heat

1.7. Conclusion

1.8. Combined heat and cold production example

2. Cold production technologies

2.1. Chillers

2.2. Absorption refrigeration machines

2.3. Thermal energy storage

2.4. Combination of mechanically driven systems and thermal energy-driven absorption systems

2.5. Conclusions

2.6. Cold production technologies example

3. Refrigerants

3.1. Introduction to refrigerants

3.2. History and evolution

3.3. Safety classifications and designations

3.4. Environmental impact

3.5. Current refrigerants and their applications

3.6. Future of the refrigerants

3.7. Conclusions

INDEX

4. Economic and environmental aspects

- 4.1. Introduction to Economic and environmental aspects
- 4.2. Density demand
- 4.3. Viability of district cooling compared to other technologies
- 4.4. Environmental impact of district cooling
- 4.5. Optimization of district cooling technologies

5. Realised projects and case studies

- 5.1. DHC Barrio La Pinada (Valencia, Spain)
- 5.2. DHC Barcelona (Spain)
- 5.3. DCN Cold Energy Recovery from Liquefied Natural Gas Vaporization (Italy)
- 5.4. Conclusion


1. COMBINED HEAT AND COLD PRODUCTION



1.1. HEATING AND COOLING PRINCIPLES

Introduction


- Heating and cooling are essential for comfort during winter and summer.
- Buildings require heating for hot water services, typically at different temperatures.
- The largest consumers of heating and cooling are in the industrial sector.
- Cooling is also crucial in food processing, storage, and transport.
- Temperature needs vary widely: cooling can go as low as -150°C , and heating can reach up to 1000°C .



1.1. HEATING AND COOLING PRINCIPLES

Introduction

- Key technical factors: durability, maintenance, simplicity, size, and safety.
- Efficiency is increasingly important for cost and environmental reasons.
- District heating and cooling networks improve efficiency and economic performance.
- They distribute heat or cooling from central or distributed sources.
- These networks optimize heat pump and chiller performance.
- Can be used to preheat or precool sources/sinks.




Connections of DCN and DHN

1.1. HEATING AND COOLING PRINCIPLES

Heat pump operation type


- Heating: Extracts heat from a source and upgrades it to a useful temperature level
- Cooling: Removes unwanted heat and rejects it to a heat sink
- Simultaneous heating and cooling: Recovers heat from cooling processes to satisfy heating demands
- Benefit: Maximizes energy efficiency by utilizing thermal energy that would otherwise be wasted



1.2. SIMULTANEOUS HEATING AND COOLING APPLICATIONS

Simultaneous heating and cooling (SHC) principle

- Heat is extracted from the cooling side (evaporator) The compressor upgrades the recovered heat to a higher temperature level
- Useful cooling and heating are produced simultaneously
- The recovered heat is supplied to heating demands instead of being rejected to the environment



1.2. SIMULTANEOUS HEATING AND COOLING APPLICATIONS

Advantages of SHC

- **Energy Efficiency:** By recovering and reusing waste heat, SHC systems significantly reduce energy consumption compared to separate heating and cooling systems.
- **Reduced Carbon Footprint:** Using waste heat minimizes reliance on fossil fuels, lowering greenhouse gas emissions.
- **Economic Savings:** Sharing infrastructure for heating and cooling reduces capital and operational costs for the network.
- **Flexibility:** SHC systems are adaptable to varying demands for heating and cooling, making them ideal for mixed-use developments (Ex., residential, commercial, and industrial areas).
- **Peak Load Management:** SHC systems smooth energy demand peaks by simultaneously meeting both heating and cooling needs.


Challenges of SHC

- **Initial Investment:** High upfront costs for infrastructure and heat pump systems.
- **Complex System Design:** Requires precise engineering and sizing to balance simultaneous heating and cooling loads.
- **Energy Storage:** Effective TES systems are crucial to handle mismatched heating and cooling demands over time.
- **Integration with Renewable Energy:** Coupling SHC systems with renewable energy sources (Ex., solar thermal or geothermal) can enhance sustainability but requires careful planning.
- **Control:** Heating and cooling must always be consumed, transported, stored, or dissipated to have proper control of temperatures.


1.3. TECHNOLOGY FOR HEAT PUMP AND CHILLERS

Emerging Technologies and Future Trends

1. Natural Refrigerants
2. High-Temperature Heat Pumps
3. Digitalization and IoT
4. Thermoelectric and Magnetocaloric Cooling
5. Hybrid Systems
6. Integration with District Energy Systems




Magnetocaloric heat pump/chiller



High temperature heat pump

1.4. CURRENT TECHNOLOGY

Compressors




1.4. CURRENT TECHNOLOGY

Thermal energy storage

1. Short/Long term thermal storage
2. Sensible/latent/chemical thermal storage
3. Distributed/localized thermal storage
4. Fixed/mobilized thermal storage

TES used in DH systems can be classified on the basis of different criteria




1.5. INTEGRATION

Possibilities of integration

A combination of urban and industrial heating and cooling consumptions by a heat pump with the possibility of simultaneous production.

	Application	Temperature Range	Traditional Technology
Heat source	Ambient air	0 – 30 °C (15 °C)	Several technologies
	Data cooling center	20 – 50 °C (35°C)	R-410A based cooling technology
	Low-temperature district heating	40 – 70 °C (55 °C)	Mix technologies (waste-to-heat, gas boiler, coal, etc.)
Heat sink	Low-temperature space heating	35 – 50 °C	Solar, electric or gas boiler
	Domestic hot water	45 – 65 °C	Electric or gas boiler
	Industrial processes /	75 – 90 °C	Centralised gas burned system
	Heating radiators		






1.5. INTEGRATION

Influence of the operational temperatures

Depending on the temperature of the heat sink and the heat source, the COP will vary significantly.

COP represents the kW of heating or cooling per kW of electricity absorbed.

A higher COP represents lower energy consumption, lower operational costs, and lower CO2 emissions. (a higher potential of decarbonization)




1.5. INTEGRATION


Combination with DHN, DCN, and industrial processes: energy perspective

A higher difference between heat sink and heat source will require more than one stage in the vapor compression cycle of the heat pump. Moreover, the Internal Heat Exchanger can benefit energy performance, depending on the refrigerant and application.

Two-Stage Cascade



Scenarios	T _o (°C)	T _k (°C)	Configuration of cycle	Process	Configuration of the connection
Scenario 1	30	80	SS/TSC	Industrial (cooling dissipation water) and heat supply (conventional boiler substitute) supply heat to 4G District Heating Network (DHN).	C_HP_DHN
Scenario 2	30	65	SS	Cooling dissipation water (heat recovery) and supply heat to 4G District Heating Network (DHN).	C_HP_DHN
Scenario 3	2	65	SS/TSC	Simultaneous production of DHN heating (70–40 °C) and DCN cooling (17–7 °C) 4G.	C_HP_DHC
Scenario 4	2	45	SS	Simultaneous production of DHN heating (47–40 °C) and DCN cooling (17–7 °C) 4G.	C_HP_DHC
Scenario 5	50	90	SS	Heat production (conventional boiler substitute) sourced from DHN (70–40 °C) 4G.	L_HP_DHN
Scenario 6	10	90	TSC	Heat production (conventional boiler substitute) sourced from DHN (<40 °C) 5G.	L_HP_DHN





Ghad Alarnaot Alarnaout, Joaquín Navarro-Esbrí, Adrián Mota-Babiloni, Operational, economic, and carbon footprint feasibility of a moderately-high-temperature heat pump as an alternative to conventional boilers in various scenarios, *Energy Conversion and Management*, Volume 309, 2024, 118424, ISSN 0196-8904, <https://doi.org/10.1016/j.enconman.2024.118424>.

1.5. INTEGRATION

Combination with DHN, DCN, and industrial processes: economic perspective



Operational and investment costs depend significantly on the applications considered, while a fossil fuel boiler is mainly affected by the heating requirement. Each situation must be studied in detail to see which combination can reduce costs and make the investment more attractive.



1.5. INTEGRATION

Combination with DHN, DCN, and industrial processes: Environmental perspective

The COP obtained clearly influences the sustainability of the solution once environmentally friendly refrigerants are chosen. Another critical factor is the electricity grid and the carbon emission factor (the origin of the electricity generated).




Ghad Alarnaot Alarnaout, Joaquín Navarro-Esbrí, Adrián Mota-Babiloni, Operational, economic, and carbon footprint feasibility of a moderately-high-temperature heat pump as an alternative to conventional boilers in various scenarios, *Energy Conversion and Management*, Volume 309, 2024, 118424, ISSN 0196-8904, <https://doi.org/10.1016/j.enconman.2024.118424>.

1.5. INTEGRATION

Combined COP

Combined or aggregated COP considers that the heat pump's heat transfer output is cooling and heating (quantified by the EER and COP, respectively). At the same time, electricity is the input as it is dissipated from the ambient.





Ghad Alarnaot-Alarnaout, Joaquín Navarro-Esbrí, Ángel Barragán-Cervera, Adrián Mota-Babiloni, Energy, exergy, economic, and environmental (4E) assessment of an experimental moderately high-temperature heat pump for district heating and cooling networks, *Energy Conversion and Management*, Volume 325, 2025, 119346, ISSN 0196-8904, <https://doi.org/10.1016/j.enconman.2024.119346>.

1.5. INTEGRATION

Comparison with fossil fuel boiler


The economic benefit compared to fossil fuel boiler is significant, but it depends on the operational temperatures




Ghad Alarnaot-Alarnaout, Joaquín Navarro-Esbri, Ángel Barragán-Cervera, Adrián Mota-Babiloni, Energy, exergy, economic, and environmental (4E) assessment of an experimental moderately high-temperature heat pump for district heating and cooling networks, Energy Conversion and Management, Volume 325, 2025, 119346, ISSN 0196-8904, <https://doi.org/10.1016/j.enconman.2024.119346>.

1.6. WASTE AND RENEWABLE HEAT


Example 1. A Novel compound waste heat-solar driven ejector-solar assisted heat pump for simultaneous heating and cooling purposes.



Cooling mode



Heating mode with PV/T waste heat




Heating mode with milk waste heat

1.6. WASTE AND RENEWABLE HEAT


Example 2

A novel compound PV/T (photovoltaic thermal) waste heat driven ejector-heat pump system for simultaneous data center cooling and waste heat recovery for district heating networks.




1.6. WASTE AND RENEWABLE HEAT

Example 3. Combined organic Rankine and compound ejector-multi evaporator vapour compression system for two cooling levels and heating purposes with power generation, geothermal and condenser waste heat utilisation.



Combined power-cooling




Combined power-heating


Ali Khalid Shaker Al-Sayyab, Adrián Mota-Babiloni, Ángel Barragán-Cervera, Joaquín Navarro-Esbrí, Dual fluid trigeneration combined organic Rankine-compound ejector-multi evaporator vapour compression system, Energy Conversion and Management, Volume 267, 2022, 115876, ISSN 0196-8904, <https://doi.org/10.1016/j.enconman.2022.115876>.

1.6. WASTE AND RENEWABLE HEAT


Example 4. An ORC combined with a compound greenhouse waste heat-driven ejector-VCC for energy-efficient power-cooling and heating.



Power-cooling



Power-heat pump heating



Power-ground source heating

1.7. CONCLUSIONS

- Simultaneous heating and cooling is possible with heat pumps/chillers
- It allows for maximizing the energy output of the heat pump. Otherwise, it would be wasted.
- DHN and DCN are ideally suited for maximizing profit and reducing the need for expensive peak shifting strategies or larger thermal energy storage.
- Heat pumps can use several compressor technologies, depending mainly on the unit's thermal capacity and the pressure ratio set by the application.
- Simultaneous heating and cooling contribute to better operational conditions for the heat pump.
- Energy efficiency is vital for making heat pumps competitive compared to boilers.
- Heat pumps are particularly efficient when their components use renewable or waste heat. A wide variety of heat sources can be considered.

2. COLD PRODUCTION TECHNOLOGIES




2.1. CHILLERS

Introduction

A chiller **removes heat** from a process, machinery, or building to maintain a controlled temperature. This is done by circulating a cooled fluid (often water or a water-glycol mixture) that absorbs heat from the target area and transfers it to the environment.

They are commonly used in **industrial, commercial, and HVAC** (heating, ventilation, and air conditioning) systems to cool equipment, processes, or buildings. Therefore, **from hundreds to thousands of kW** of cooling.


Chillers are widely used in industries such as **manufacturing, medical facilities, data centers,** and food processing to maintain optimal temperatures.



2.1. CHILLERS

Operation

- Chiller cycle work same as heat pump cycle but focuses in only cooling
- At the evaporator, the heat is absorbed exchanging heat with liquid water
- The heat is rejected exchanging it with air (usually at the roof)
- The unit that contain the fans to reject the heat are called condensing units



2.1. CHILLERS

Types of Chillers



Chillers are classified based on how they dissipate heat:

1. Air-Cooled Chillers:

1. Use fans to blow air over a condenser coil to release heat.
2. Ideal for small to medium-sized systems or where water access is limited.
3. Common in commercial HVAC systems.

2. Water-Cooled Chillers (Centrifugal):


1. Use water and cooling towers to dissipate heat more efficiently.
2. Suitable for large-scale industrial applications where greater efficiency is required.



2.1. CHILLERS

Water-cooled chiller

Water cooled chiller cycle reject the heat using water instead of air, then the water is cooled at the cooling tower and reintroduced to the condenser.




Range: 50 kW to 10000 kW



2.1. CHILLERS

Air-cooled chiller

Air cooled chiller is the basic chiller, the refrigerant is directly cooled with air, that means the heat is rejected directly to the ambient.



Range: 15 kW to 1500 kW



2.1. CHILLERS

Key Metrics and Efficiency

- **Cooling Capacity ($\dot{Q}_o$):** Measured in tons of refrigeration or kilowatts (kW), indicating the amount of heat removed.
- **Power Consumption ($\dot{W}_c$):** Compressors consume (kW) the most electricity in the system, making their design critical for efficiency. Water pumps and fans must be considered as they can represent 10% of the consumption.
- **Energy efficiency ratio (EER):** A measure of efficiency calculated as the ratio of cooling provided to energy consumed (kW cooling / kW electricity).

$$EER = \frac{\dot{Q}_o}{\dot{W}_c}$$

- **Seasonal energy efficiency ratio (SEER):** Like the EER, but over an entire season, by calculating the cooling output divided by total electric energy input (kWh cooling / kWh electricity).

2.1. CHILLERS

Seasonal energy efficiency ratio (SEER)

- SEER uses a set indoor temperature, along with different outdoor temperatures and load capacities to simulate real life.
- The EN 14825 standard defines the test methodology.

		Capacity			
		100%	74%	47%	21%
Outdoor temperature	Air source	35 °C	30 °C	25 °C	20 °C
	Water source	30 °C	26 °C	22 °C	18 °C

- Energy efficiency class depends on SEER and type of equipment. Between A+++ and G, being the first the most efficient classification.


2.1. CHILLERS

System performance

It depends on:

- Good design and professional installation of the entire system.
- Regular maintenance.
- The size of the building being conditioned and its energy efficiency.
- The size of the system and its air handling capacity.
- The amount of time the system is used daily.
- The indoor temperature.
- The outdoor air temperature.

AC	CHF	
≥ 5.05	≥ 5.1	A
$4.65 \leq \text{EER} < 5.05$	$4.9 \leq \text{EER} < 5.1$	B
$4.25 \leq \text{EER} < 4.65$	$4.7 \leq \text{EER} < 4.9$	C
$3.85 \leq \text{EER} < 4.25$	$4.5 \leq \text{EER} < 4.7$	D
$3.45 \leq \text{EER} < 3.85$	$4.3 \leq \text{EER} < 4.5$	E
$3.05 \leq \text{EER} < 3.45$	$4.1 \leq \text{EER} < 4.3$	F
< 3.05	< 4.1	G



2.1. CHILLERS


Applications of Chillers

- HVAC Systems
- Industrial Processes (Food processing, plastic processing, metal finishing...)
- Data Centers
- Refrigeration
- Healthcare
- Power plants
- Ice rinks
- **District Cooling**



2.1. CHILLERS

Integration of Chillers into DCN




There are two main considerations when incorporating a chiller into a DCN: firstly, the type of chiller used is usually water-cooled as DCN requires high-capacity chillers, and managing high flows requires water cooling. Furthermore, thermal energy storage is always required to supply the required demand of the district at different times.

2.2. ABSORPTION REFRIGERATION MACHINES

Absorption refrigeration

Main Components:

1. **Evaporator:** Where the refrigerant absorbs heat and evaporates.
2. **Absorber:** Where the refrigerant vapor is absorbed by the absorbent fluid.
3. **Generator:** Where the refrigerant is separated from the absorbent using heat, regenerating the refrigerant.
4. **Condenser:** Where the refrigerant releases heat and condenses back into a liquid.



2.2. ABSORPTION REFRIGERATION MACHINES

Types of Absorption Refrigeration Systems

Two main refrigerant/absorbent pairs are used based on temperature range:

1. Ammonia–Water ($\text{NH}_3\text{--H}_2\text{O}$) – for applications below 50 °C

Ammonia acts as the refrigerant, water as the absorbent. Common in industrial cooling.

Pros: High performance in low-temperature applications

Cons: Water is volatile, requiring a rectifier; system is complex. Ammonia is flammable, toxic, and incompatible with copper/brass, so systems are built from steel.

2. Water–Lithium Bromide ($\text{H}_2\text{O--LiBr}$) – for applications above 50 °C

Water is the refrigerant, LiBr the absorbent. Widely used in air conditioning and hot water for large buildings.

Pros: High safety, stability, strong affinity, and latent heat; adjustable load via absorbent reconcentration

Cons: Risk of crystallization near 0 °C; operates under vacuum; high viscosity; air leakage risk.

2.2. ABSORPTION REFRIGERATION MACHINES

Relevant Parameters

Cooling Capacity ($\dot{Q}_o$): The amount of heat removed by the evaporator from the space or process being cooled, typically measured in kW.

Heat Input ($\dot{Q}_g$): The heat required to drive the absorption cycle, typically provided by a heat source like natural gas, waste heat, or solar energy. It is often measured in kW.

Coefficient of Performance (COP): The cooling capacity (Q_o) ratio to the heat input (Q_g).

$$COP = \frac{\dot{Q}_o}{\dot{Q}_g}$$

COP is a key performance indicator of energy efficiency. A higher COP indicates a more efficient system. In absorption refrigeration, typical COP values range from 0.5 to 1.5, significantly lower compared to vapor compression systems.

2.2. ABSORPTION REFRIGERATION MACHINES

Compared to vapor compression systems:

Compression systems	Absorption systems
Work operated	Heat operated
High COP	Low COP (currently maximum ≈ 1.4)
Performance (COP and capacity) very sensitive to evaporator temperatures	Performance not very sensitive to evaporator temperatures
System COP reduces considerably at part loads	COP does not reduce significantly with load
Liquid at the exit of evaporator may damage compressor	Presence of liquid at evaporator exit is not a serious problem
Performance is sensitive to evaporator superheat	Evaporator superheat is not very important
Many moving parts	Very few moving parts
Regular maintenance required	Very low maintenance required
Higher noise and vibration	Less noise and vibration
Small systems are compact and large systems are bulky	Small systems are bulky and large systems are compact
Economical when electricity is available	Economical where low-cost fuels or waste heat is available


2.3. THERMAL ENERGY STORAGE (TES)

Introduction to TES

Thermal energy storage (TES) stores heat or cooling for later use, separating generation from consumption.

The concept is similar to electrical batteries, but instead of storing electricity, heating or “cooling” is stored, increasing a fluid’s temperature, or using phase change (generally solid to liquid and viceversa).


This means that heating or cooling can be generated when an extra surplus or renewable electricity, or waste heat, is available and then consumed when needed. This is especially interesting in DCNs, where central or waste cooling is independent of individual or industrial consumers.



2.3. THERMAL ENERGY STORAGE (TES)

Main benefit of TES

- In DCNs, TES typically involves storing cool energy in an insulated water tank. The tank is **cooled or frozen during off-peak periods** (nights or weekends) and **melted or warmed during on-peak periods** (weekdays).
- This reduces the need for large chillers during peak demand by discharging TES to meet some or all of the load. Extra chiller capacity charges TES during off-peak times while meeting off-peak cooling loads.
- Lower-capacity chillers reduce investment and operational costs and reduce electrical stress from the grid.



2.3. THERMAL ENERGY STORAGE (TES)

Type of TES

	Ice storage tank	Chilled water storage tank	Low-temperature liquid storage tank
Type of storage	Latent heat	Sensible heat	Latent heat
Discharge temperature	1°C to 7°C	4°C to 6°C	-1°C to 2°C
Recharge temperature	-8°C to -2°C	4°C to 6°C	-1°C to 2°C
Recharge chiller plant and power (kW electricity in/kW thermal out)	0.8 to 1.1 kW/ton (0.23 to 0.31)	0.6 to 0.7 kW/ton (0.23 to 0.31)	0.7 to 0.8 kW/ton (0.23 to 0.31)

2.3. THERMAL ENERGY STORAGE (TES)

Applications

- **Educational facilities:** schools, colleges, and universities
- **Healthcare facilities:** hospitals, clinics, laboratories, and medical research
- **Airports, museums:** and sports and entertainment complexes
- **Government facilities:** institutional; military; research; administrative; and correctional facilities, at federal, state, and local levels
- **Private industry:** commercial and industrial facilities (including aeronautics and aerospace, automotive, computing, data processing, electronics, pharmaceuticals, telecommunications)
- **District cooling utilities:** CHW utility systems selling cooling to multiple customers
- **Energy services/Performance Contracting:** third-party financed projects, funded by energy-efficiency-related cost savings
- **Turbine inlet cooling:** increasing hot-weather power output and efficiency of combustion turbine power plants

2.3. THERMAL ENERGY STORAGE (TES)



Integration of TES into DCN

TES: stores cold for later use

DCN: balances supply and demand

Benefits: reduces peak load and improves system flexibility

Impact: increases overall efficiency and enables better use of renewable and waste heat



Thirkell Consulting Engineers. (n.d.). District cooling system with large scale thermal energy water storage. <https://www.thirkell.com.au/tropicalbuild/case-studies/district-cooling-system-with-large-scale-thermal-energy-water-storage>

2.3. THERMAL ENERGY STORAGE (TES)

General benefits of integration of TES into DCN:

- The **overall cost of the installation is lower** due to the reduction of the refrigeration plant installed capacity. The refrigeration equipment size is smaller because it is designed for average loads rather than peaks.
- **Operational costs are reduced** compared to an online cooling system because peak consumption can be avoided during high electrical tariff periods.
- The environmental impact is reduced because of the reduction of CO₂. Storing the energy and improving operating efficiency with the thermal energy storage tank helps **reduce the CO₂ emissions** of a district cooling system even more.
- The **plant dimension of the refrigeration system could be reduced**. This is given by the fact that the refrigeration capacity of energy produced by the plant will be lower due to the energy already accumulated in the tank. Therefore, a smaller refrigeration system can be used.


4. COMBINATION OF MECHANICALLY DRIVEN SYSTEMS AND THERMAL ENERGY-DRIVEN ABSORPTION SYSTEMS

Introduction

A combination of **mechanically driven systems** (such as vapor compression refrigeration) and **thermal energy-driven absorption systems**.

It integrates two distinct cooling technologies to enhance overall system performance, energy efficiency, and sustainability.

They can be **combined through the condenser**, in which the heat rejected by the vapor compression system is used as useful heat by another cycle, as the absorption system. Otherwise, this heat would be rejected to the ambient, and lost. It consequently maximizes the energy efficiency of the overall system.



Turgut, M., & Turgut, O. (2019). Comparative investigation and multi objective design optimization of a cascaded vapor compression absorption refrigeration system operating with different refrigerants in the vapor compression cycle. *Heat and Mass Transfer*, 55. <https://doi.org/10.1007/s00231-018-2430-3>

2.4. COMBINATION OF MECHANICALLY DRIVEN SYSTEMS AND THERMAL ENERGY-DRIVEN ABSORPTION SYSTEMS

Key parameters

In this case, the COP considers the whole system inputs and outputs:

- COP_c : combined coefficient of performance (whole system)
- $\dot{Q}_{cas,cond}$: cascade condenser load
- $\dot{Q}_g$: heat load input
- $\dot{W}_c$: compressor power consumption
- $\dot{W}_p$: pump power consumption

$$COP = \frac{\dot{Q}_{cas,cond}}{(\dot{Q}_g + \dot{W}_c + \dot{W}_p)}$$

2.4. COMBINATION OF MECHANICALLY DRIVEN SYSTEMS AND THERMAL ENERGY-DRIVEN ABSORPTION SYSTEMS

Applications of this system

- Industrial Refrigeration
- District Cooling Systems
- Combined Heat and Power (CHP) Plants
- Combined Heating and Cooling (CHC)
- Chemical and Petrochemical Industries
- Data Centers

District Heating and Cooling with Waste Heat Recovery

- Refrigerated Transport
- Ice Rinks and Sports Arenas
- Pharmaceutical and Medical Applications
- Solar Cooling System

However, they are not widely used because of the costs and complexity. Technological advancements or regulations promoting their use are required to enter into the market.

2.5.CONCLUSIONS

- Air-cooled and Water-cooled chillers present significant differences in advantages and drawbacks.
- COP and EER quantify the nominal operation of the heat pumps and chillers.
- Seasonal COP and EER consider round-season operation, providing a more detailed picture of the actual consumption.
- Absorption chillers activate using heat instead of electricity. They can be gas-fueled, but their sustainability is maximized when combined with renewable, waste heat, or district heating networks.
- Two fluids in absorption chillers must be considered for the particular application.
- Thermal energy storage is considered sensible heat storage (hot water tank). However, phase change materials and thermochemical energy storage are promising in the mid and long-term.
- A combination of vapor compression and absorption systems can maximize cooling generation. This is particularly useful in simultaneous heating and cooling applications for diversifying thermal energy production and peak shifting.

3. REFRIGERANTS




3.1. INTRODUCTION TO REFRIGERANTS

Definition:

According to the International Institute of Refrigeration (IIR): A refrigerant is a substance or mixture, typically fluid, used in a refrigeration cycle to

- **absorb heat at a low temperature and pressure and**
- **release it at a higher temperature and pressure.**

This heat transfer occurs as the refrigerant changes phase, typically from liquid to gas and vice versa, enabling cooling or heating in applications like refrigeration, air conditioning, and heat pumps.



Super Radiator Coils. (n.d.). Custom commercial & industrial heat exchangers. <https://www.superradiatorcoils.com/>

Sdya Chem. (n.d.). Refrigerant R600a isobutane gas. <https://es.sdya-chem.com/refrigerant-gas/isobutane-r600a/refrigerant-r600a-isobutane-gas.html>

Advanced Commercial. (n.d.). Commercial HVAC, refrigeration, plumbing & building automation solutions. <https://advanced-commercial.com/>

3.1. INTRODUCTION TO REFRIGERANTS

Primary refrigerant vs. Secondary refrigerant


Primary refrigerant, also known as working fluid.

- *Rejects heat at **higher pressure/temperature***
- *Absorbs it at a **lower pressure/temperature***

Secondary refrigerant, also known as:


- Secondary fluid
- Secondary coolant
- Heat transfer fluid

Any fluid used for transferring heat from the products to be cooled to the primary refrigerant



3.1. INTRODUCTION TO REFRIGERANTS

Basic classification




Pure Fluid: Pressure and temperature are constant under phase change, so one can define the other.

During phase change:
 $P \rightarrow T$ and $T \rightarrow P$

3.1. INTRODUCTION TO REFRIGERANTS


Basic classification



Azeotropic mixture:
 The composition and the zeotrope temperature do not appreciably change as the azeotrope evaporates or condenses under constant pressure.

3.1. INTRODUCTION TO REFRIGERANTS

Basic classification



Zeotropic mixture: Under constant pressure, during the liquid-vapor phase change, the temperature and composition of a zeotrope vary. P-T needs another parameter to be defined



3.1. INTRODUCTION TO REFRIGERANTS

Basic classification

Mixtures:

Zeotropic mixtures requires special measures for properties determination, parameters calculation, manipulation, etc.


A zeotropic mixture with a lower temperature glide (below 0,5 to 1 K, depending on the source) is called near-azeotropic and can be considered an azeotropic mixture in practical terms.



SWEP International AB. (n.d.). Brazed plate heat exchangers for HVAC and industrial applications. <https://www.swepgroup.com/>

Silva-Alvarado, O., Sánchez-Cruz, F. A., & [Other Authors]. (2022). Zeotropic refrigerants: Image analysis for void fraction measurement at evaporator's inlet for R-404A. In *Memorias del XXVIII Congreso Internacional Anual de la SOMIM* (pp. 162–[End Page]). Sociedad Mexicana de Ingeniería Mecánica. https://somim.org.mx/memorias/memorias2022/articulos/A4_107.pdf

3.2. HISTORY AND EVOLUTION




Mota-Babiloni, Adrián. (2016). Analysis of low Global Warming Potential fluoride working fluids in vapour compression systems. Experimental evaluation of commercial refrigeration alternatives. 10.13140/RG.2.1.1444.5685.

3.3. DESIGNATION AND PROPERTIES


Designation

ASHRAE Standard 34- provides a naming system for common refrigerants and assigns safety classifications to them.

Propane-derived chains (3 carbon atoms)



Hydrofluoro-olefins, isomers and stereo-isomers



For **double bonds**, **cis** (substitutes on the same the same side of the double bond) and **trans** configurations (substitutes on opposite sides of the double bond) may need to be indicated.

For HFO-1336mzz(Z), the '**m**' indicates **CF₃** (letters from a to l indicate other groups) and the **two 'z' s** indicate **H on the central carbon C=C**

3.3. DESIGNATION AND PROPERTIES

Properties: Safety

Toxicity

Flammability

Defined by ASHRAE 34 (International), then EN378 (Europe), then depends on the country

		Lower Toxicity	Higher Toxicity
Increasing flammability ↑	Higher Flammability	A3	B3
	Lower Flammability	A2	B2
		A2L	B2L
	No Flame propagation	A1	B1
		Increasing toxicity	

The classification influences the maximum refrigerant amount of charge for each refrigeration application


A: Toxicity has not been identified at concentrations ≤ 400 ppm by vol.

3.4. ENVIRONMENTAL IMPACT

Environmental metrics summary

- **ODP:** Measures the stratospheric ozone decomposition compared to R-11.
- **GWP:** Measures the relative heat-trapping impact of a refrigerant compared to CO₂ over a specific time.
- **TEWI:** Evaluates the combined warming effect of refrigerant leaks and energy consumption but does not include manufacturing.
- **LCCP:** Accounts for the total climate impact over a refrigerant's full life cycle, including production, use, and disposal.
- **LCA:** Broadly assesses environmental impacts across multiple categories throughout a product's life.

Graphical representation for CO₂ equivalent emissions:



3.4. ENVIRONMENTAL IMPACT

GWP

Global Warming Potential (GWP) measures the relative impact of a greenhouse gas in terms of its heat-trapping ability over a specific time period, typically 20, 100, or 500 years, compared to carbon dioxide (CO₂), which has a GWP of 1 by definition. GWP considers the amount of energy a gas absorbs, its atmospheric lifetime, and its concentration over time. The GWP of a substance over a time period t is given by the equation:

$$\text{GWP}_{\text{gas},t} = \frac{\int_0^t a_{\text{gas}} \cdot C_{\text{gas}}(t) dt}{\int_0^t a_{\text{CO}_2} \cdot C_{\text{CO}_2}(t) dt}$$

where:

a_{gas} : Radiative efficiency of the gas (how much heat it traps per unit mass).

$C_{\text{gas}}(t)$: Concentration of the gas in the atmosphere over time. t : Time horizon (typically 20, 100, or 500 years).

a_{CO_2} : Radiative efficiency of CO₂.

$C_{\text{CO}_2}(t)$: Concentration of CO₂ over time.

GWP informs us how much a given mass of a refrigerant (or other greenhouse gases) contributes to global warming compared to the same mass of CO₂.

3.4. ENVIRONMENTAL IMPACT

TEWI

1) Direct Emissions: Refrigerant accidental leakage and losses during the operation, maintenance, and end-of-life disposal phases. It's calculated as:

$$\text{Direct Emissions} = \text{Leakage Rate} \times \text{Charge} \times \text{GWP} + \text{End-of-Life Emissions} \times \text{Charge} \times \text{GWP}$$

- Leakage Rate: Annual leak percentage of the refrigerant.
- Charge: Total refrigerant charge (mass of refrigerant in the system).
- End-of-Life Emissions: Percentage of refrigerant lost or not recovered at disposal.

2) Indirect Emissions: CO₂ equivalent emissions resulting from the energy consumption of the system over its lifespan. It's calculated as:

$$\text{Indirect Emissions} = \text{Annual Energy Use} \times \text{Lifespan} \times \text{Emission Factor}$$

- Annual Energy Use: The energy consumed by the system in one year.
- Lifespan: Expected operating lifetime of the system.
- Emission Factor: CO₂ emissions per unit of energy consumed, depending on the electricity generation mix.

3.4. ENVIRONMENTAL IMPACT

LCCP

Life Cycle Climate Performance (LCCP) assesses the **total climate impact** of a refrigerant throughout its **lifecycle**, accounting for both direct and indirect emissions. Direct emissions occur when the refrigerant is released (through leaks or disposal), while indirect emissions come from the energy required to operate refrigerant equipment. The general formula for LCCP is:

$$\text{LCCP} = E_{\text{direct}} + E_{\text{indirect}} + E_{\text{manufacturing}} + E_{\text{end-of-life}}$$

- E_{direct} : Direct emissions from refrigerant leaks or releases during operation and servicing:

$$E_{\text{direct}} = \text{GWP} \times \text{leaked amount}$$

- E_{indirect} : Indirect emissions from energy used by the system:

$$E_{\text{indirect}} = \text{Total Energy Use} \times \text{Emission Factor of Energy Source}$$

- $E_{\text{manufacturing}}$: Emissions from refrigerant production and transport.
- $E_{\text{end-of-life}}$: Emissions from disposal or recovery at the end of the system's life.

3.4. ENVIRONMENTAL IMPACT

LCA

Life Cycle Assessment (LCA) is a systematic evaluation of the environmental impacts associated with all stages of a product's lifecycle, from raw material extraction, production, use, and disposal. Unlike LCCP, LCA covers various impact categories beyond climate change, such as resource depletion, acidification, and eutrophication.

The Life Cycle Impact of a refrigerant or system can be calculated with:


$$LCA_{\text{total}} = \sum_{i=1}^n \text{Inventory}_i \times \text{Impact Factor}_i$$

Inventory_i: Quantity of each environmental factor (e.g., CO₂ emissions, water usage, energy consumption) at each stage of the life cycle.

Impact Factor_i: Coefficient representing the environmental impact per unit of each factor.

3.5. CURRENT REFRIGERANTS AND APPLICATIONS

Most regulations over time




3.5. CURRENT REFRIGERANTS AND APPLICATIONS

TFA

Trifluoroacetic acid (TFA): organofluorine compound $\text{CF}_3\text{CO}_2\text{H}$

- Formed from atmospheric decomposition of refrigerants (degradation product).
- Report from the German Federal Environment Agency.
- 5% of human origin (manufacturing, agriculture, wastewater treatment and refrigerants).
- **R1234yf produces 100% TFA, R134a between 7 and 20%, R1234ze(E) less than 10%**
- **R1336mzz(Z) produces less than 20%, R1233zd(E) only 2%.**



3.5. CURRENT REFRIGERANTS AND APPLICATIONS

PFAS

Perfluorinated and polyfluorinated alkyl substances (PFAS)

- Over 4,700 “forever chemicals”
- PFAS can be harmful to human health.
- They cover a range of fluorinated gases, including certain HFCs (R134a, R125, R143a, and R152a) and HFOs (R1234yf, R1234ze(E), and R1233zd(E)) used in HVAC&R applications. TFA is a PFAS (CF₃- and CF₂-)
- The state of Maine, USA, became the first government to ban the sale of products containing PFAS as of January 1, 2030
- See Report Norwegian Environment Agency




3.5. CURRENT REFRIGERANTS AND APPLICATIONS

Natural refrigerants

Natural refrigerants are seen as a safer and more sustainable option to replace HFOs.


These refrigerants do not generate harmful by-products like TFAs or HF during their breakdown in the atmosphere, and they have no Ozone Depletion Potential (ODP) and a much lower GWP.

The most common ones are: CO_2 , NH_3 , and Hydrocarbons.



3.6. FUTURE OF THE REFRIGERANTS

Observing the history and evolution, the actual tendency is to return to the natural refrigerants as they do not present ODP, low GWP, do not form TFA. However, the safety of those refrigerant need to be considered and develop strategies to make the facilities that contain natural refrigerants safe.



3.5. CURRENT REFRIGERANTS AND APPLICATIONS

Most commonly used refrigerants (synthetic)

Refrigerant	Type	Application	GWP	Safety classification
R-410A	HFC	Common in reversible heat pumps, though its high GWP is leading to its phase-out in favor of lower-GWP refrigerants.	2088	A1
R-32	HFC	Residential and small commercial systems as a lower-GWP alternative to R-410A.	675	A2L
R-134a	HFC	Widely used in commercial applications, though being phased out for its high GWP.	1430	A1
R-513A	HFO/HFC	Used in commercial and industrial applications as a low-GWP replacement for R-134a.	573	A1
R-450A	HFO/HFC	Another low-GWP replacement for R-134a in systems that need dual-purpose heating and cooling.	547	A1
R-1234yf	HFO	Primarily used in automotive air conditioning and increasingly in heat pumps for industrial and commercial systems.	<1	A2L
R-1234ze(E)	HFO	Industrial and commercial systems.	<1	A2L
R-1233zd(E)	HFO	Primarily used in large chillers and heat pumps for industrial and commercial buildings.	1	A1

3.5. CURRENT REFRIGERANTS AND APPLICATIONS

Most commonly used refrigerants (natural)

Refrigerant	Type	Application	GWP	Safety classification
R-744 (CO ₂)	Natural	Used in commercial and industrial refrigeration, heat pumps for water heating, and supermarkets. CO ₂ is favored for its very low GWP, though its high operating pressure requires specialized system designs.	1	A1
R-290	Natural	Employed in residential and commercial systems for both heating and cooling, particularly in low- to medium-capacity systems.	3	A3
R717 (NH ₃)	Natural	Primarily used in large industrial and commercial refrigeration, such as food processing and cold storage	0	B2L
R-600	Natural	Used in small refrigeration appliances, such as domestic refrigerators and some commercial freezers.	3	A3
R-600a	Natural	Commonly used in domestic refrigerators, small commercial freezers, and heat pumps.	3	A3

3.7. CONCLUSIONS

- The history of refrigerants helps us understand standard requirements
- Once commercial refrigeration and heat pump applications were commercialized, most efforts were directed at finding the most sustainable refrigerant.
- For every application, there is one optimum refrigerant. However, the perfect refrigerant does not exist.
- A trade-off between thermodynamic, technical, safety, economic, and environmental perspectives is always required.
- Alternative refrigerants for existing and new systems (drop-in or retrofit) differ. The latter are considered when different safety requirements or operational conditions exist.
- The future will be oriented to natural refrigerants to avoid all environmental concerns.
- DHN and DCN can help transfer heat and use refrigerants with stricter safety requirements, as big and isolated vapor compression systems can be designed.

4.1. INTRODUCTION TO ECONOMIC AND ENVIRONMENTAL ASPECTS

Alternative to

- Split ACs, heat pumps, chillers, VRF systems
- Traditional systems = one unit per apartment or zone

DCN Advantages

- Centralized cooling for multiple buildings
- Higher energy efficiency
- Lower equipment costs
- Greater sustainability with equal comfort


Challenges

- High infrastructure investment (cooling pipelines)
- Economic feasibility depends on scale and context
- Fewer sources of waste cooling

Considerations


- Shares pros/cons with district heating
- Influenced by legal and political frameworks

Investment cost per trench length, EUR/m



4.2. DENSITY DEMAND

Cooling demand (2015), Castellón, Spain




This is an example of municipalities in Spain that present an opportunity to implement district cooling (high density demand)

4.2. DENSITY DEMAND

Density cutoff

Cost of Cooling Technologies vs. Cooling Density



- ① Conventional cooling costs do not depend on cooling density
- ② District cooling costs decrease with increasing cooling density because of lower relative network costs
- ③ District cooling is more cost effective than conventional cooling only where cooling densities are above the "density cutoff"

Note: RT/km² = refrigeration tons per square kilometer. Levelized Cost = price required to break even.

Source: Strategy&

4.2. DENSITY DEMAND

Analysis of density demand (1)

1. Data Collection & Preprocessing

- **Building Data:** Types, usage (residential, commercial, industrial), sizes, occupancy, historical demand
- **Climate Data:** Temperature, humidity, solar radiation
- **Energy Patterns:** Peak vs. off-peak consumption profiles

2. Cooling Load Estimation

- **Dynamic Simulation Tools:** e.g., TRNSYS, EnergyPlus
- **Hourly cooling loads** based on envelope, HVAC, internal gains
- **Peak Load Identification:** Crucial for sizing system components



4.3. VIABILITY OF DISTRICT COOLING COMPARED TO OTHER TECHNOLOGIES

1. **Capital Costs:** DCN systems have high upfront costs, but economies of scale make them cost-effective in dense areas, unlike cheaper standalone systems with duplicated equipment.
2. **Operational Costs:** DCN systems are more energy-efficient and cheaper to maintain due to centralized operations, while conventional systems have higher long-term costs.
3. **Long-Term Savings:** DCN offers significant cost savings over time, whereas standalone systems incur higher total ownership costs.
4. **Revenue:** DCN creates stable revenue streams via contracts, unlike conventional systems.
5. **Risk:** DCN has higher initial financial risk but stable long-term benefits; conventional systems have lower startup risks but volatile operating costs.
6. **External Benefits:** DCN reduces urban peak loads and supports local economies, whereas standalone systems have limited broader impact.




4.3. VIABILITY OF DISTRICT COOLING COMPARED TO OTHER TECHNOLOGIES

Carbon Emissions

Study of Alajmi and Zedan (2020) in Kuwait.

- The total cost is reduced from 22,669 M\$ for RTU and 20,829 M\$ for VRF systems to 17,395 M\$ for the DC system.
- The RTU system needs 660,200 cooling units, the VRF system needs 220,800 cooling units, while the DC system needs only 624 Units. This influences
 - the number of labor hours required to service, maintain, and operate the units
 - space needed by the cooling system on the roof of the residential building.
 - number of spare parts required
 - the risk of refrigerant leakages increases.





4.4. ENVIRONMENTAL IMPACT OF DISTRICT COOLING

Carbon Emissions (2)

Study of Alajmi and Zedan (2020) in Kuwait.

- High CO₂ emission factor makes even more important high energy efficiency.



Ali Alajmi, Mohamed Zedan, Energy, cost, and environmental analysis of individuals and district cooling systems for a new residential city, Sustainable Cities and Society, Volume 54, 2020, 101976, ISSN 2210-6707, <https://doi.org/10.1016/j.scs.2019.101976>.

4.5. OPTIMIZATION OF DISTRICT COOLING TECHNOLOGIES

Economic optimization for operational cost reduction

Economies of Scale


- Spread capital costs over many consumers → lower per-unit cost
- Standardize equipment (chillers, pumps, pipes) → reduce construction time & cost

Modular Design

- Phase implementation → lower initial investment
- Scale system with demand → efficient capital use

Centralized Maintenance

- Simplifies servicing → reduces maintenance costs
- Use **predictive maintenance** & data analytics → minimize downtime & repair costs



4.5. OPTIMIZATION OF DISTRICT COOLING TECHNOLOGIES

Economic optimization for capital cost reduction

Energy Efficiency


- Use **high-efficiency chillers**, **variable-speed drives**, and **advanced controls**
- **Thermal energy storage** enables off-peak cooling → reduces peak electricity costs

Waste Heat Utilization

- Recover waste heat from **industry & power plants**
- Use sorption systems and evaporator cooling injection for DCN

Renewable Energy Integration

- Incorporate **solar thermal**, **geothermal**, and **low-carbon electricity**
- Solar cooling can reduce costs, especially in sunny areas (technology still evolving)
- Reduces fossil fuel dependency and stabilizes energy prices



4.5. OPTIMIZATION OF DISTRICT COOLING TECHNOLOGIES

Environmental Optimization

Low-GWP Refrigerants

- Use **natural** or **low-GWP synthetic** refrigerants
- Advanced **leak detection** and **maintenance** to minimize emissions

Decarbonized Energy Supply

- Connect to **renewable-powered grids** (wind, solar, hydro)
- Integrate **on-site renewables** (e.g., solar PV for auxiliaries)

Efficient Water Management

- Implement **closed-loop cooling systems**
- Use **non-potable sources** like treated wastewater

4.5. OPTIMIZATION OF DISTRICT COOLING TECHNOLOGIES

System Design and Technological Integration

Smart Grids & IoT Integration

- Real-time monitoring with **IoT sensors**

Dynamic load balancing & predictive analytics


- Intelligent control based on **demand, weather & prices**

Demand Response

- Shift cooling to **off-peak hours**
- Reduces energy costs & supports **renewable integration**
- Eases stress on the electrical grid

Backup & Resilient Systems

- **Redundancy** with backup chillers or thermal storage
- Maintains service during failures or peak loads
- Avoids emergency costs & ensures reliability



4.6. CONCLUSIONS

- To identify the suitability of the district cooling network, a careful study of density demand must be followed. This study must consider buildings, industrial consumers, and data centers.
- Density demand study involves additional disciplines to conventional HVAC and refrigeration projects, such as GIS.
- If carefully justified and risks minimized, a DCN serving proper density demand will be better than conventional cooling systems. Payback periods could be attractive.
- Contrary to traditional cooling systems, governments must be involved in district cooling networks' development and suitability framework and promote them from many perspectives.
- In addition to the traditional benefits of being a more energy-efficient technology, DCN can help diminish urban heat island effects, reduce waste, and facilitate the integration with sustainable technologies.
- DCN requires a more challenging control optimization to make them profitable and energy efficient, and the latest developments in IoT and communications contribute to it.

5. REALISED PROJECTS AND CASE STUDIES



5.1. BARRIO LA PINADA

Overview

Barrio La Pinada is a private urban development located in Paterna, close to the city of Valencia, which is expected to cover **320,000 m²**.

Barrio La Pinada is a new urban development that has yet to start construction. This provides the opportunity to create the network from scratch, matching the characteristics of a new network case study.

The total demand to be satisfied is 9.4 GWh (7.52 residential and 1.88 commercial).

	Supply
Technology	Geothermal/Aerothermal
Fuel used	Electricity
Maximum capacity	5 MW
Fixed costs	200,000 €
Capacity costs	500 €/Kw
Annual O&M costs	30 €/kW
Supply costs	1.4 c€/kWh

5.1. BARRIO LA PINADA

Network topology

Barrio La Pinada plans to connect all the neighborhood's demands to the district heating and **cooling** network, so almost all buildings were set as required.

The only ones left out of the case study were two at the southernmost end of the development, which correspond to a school. This choice is because those buildings have already been constructed and thus will not be part of the upcoming development. 73 buildings were connected, covering 100% of the proposed demand and only leaving out the school.

The optimization determines that only 3.3 MW of the available capacity (5 MW) would be needed to cover the project's demand. The associated capital investment of 2.14M € aligns with other geothermal energy developments.



5.1. BARRIO LA PINADA

Network solution

Pipework solution	
Length	6.76 km
Total Cost	1.35 M€
Linear Cost	200 €/m
Losses	1.85 GWh/year
Capacity	3.88 MW

Pipework solution	
Total Capacity Required	3.88 MWp
Output	11.05 GWh/year
Capital cost	2.14 M€
Operating cost: O&M	0.12 M€/year
Operating cost: heat production	0.15 M€/year

Demand solution	
Total Peak Demand	6.16 MW
Demand	9.2 GWh/year
Revenues	0.405 M€/year

5.1. BARRIO LA PINADA

Analysis

	Capital cost	Operating cost	Operating revenue	NPV
Pipework	-1.35 M€	-	-	-1.35 M€
Heat supply	-2.14 M€	-0.27 M€/year	-	-9.35 M€
Demands	-	-	0.41 M€/year	-10.74 M€
Emissions	Not included at this stage			
Network	-3.49 M€	-0.27 M€/year	0.41 M€/year	0.06 M€

5.2. DHC BARCELONA (SPAIN)

Key facts and location


DH market share	N.a.
Heating & Cooling capacity	DH: 23 MW (target: 40 MW) DC: 14 MW (target: 70 MW + 36 MW ice storage)
Heat & Cold production	DH: 12 GWh/y (target: 59 GWh/y) DC: 7.6 GWh/y (target: 54 GWh)
Km network (double-pipe)	12 km (target: 36 km)
CO ₂ emissions	DH: 94.9 kg/MWh DC: 0 kg/MWh (net emissions, compensated with CHP electricity production)




5.2. DHC BARCELONA (SPAIN)

DHCN projects try to enhance the available resources to supply energy, in this way the energy mix is reduced, therefore the emissions are reduced, anyway remain a dependency on fossil fuel technologies, the long-term objectives is to reduce or eliminate this dependency by increasing the proportion of renewable energies.

DC Production mix (2030)



DH Production mix (2030)



Fuel sources used for DH and DC in Ecoenergies Barcelona 2014

5.2. DHC BARCELONA (SPAIN)

Energy Demand & Supply – Barcelona (Summary)

Climate & Demand

- Subtropical-Mediterranean climate; ~1150 HDD (mild winters).
- Low heating, high and growing cooling demand.

Current Energy Mix

- Heating: Mainly natural gas (individual systems).
- Cooling: Mostly electricity-based.
- Solar Thermal Ordinance (1999): Mandatory solar DHW in new/refurbished buildings.

Energy Consumption

- Existing buildings: ~80 kWh/m²·year
- New buildings: ~45 kWh/m²·year

Market Structure

- Liberalized energy market (consumers choose suppliers).
- 5–6 suppliers cover ~90% of total supply → moderate concentration.

District Heating & Cooling (DHC)

- Regulated by Barcelona City Council via TERSA (public company).
- Prices must remain competitive with conventional energy.

Pricing

- District Heating: €42/MWh, ~10% cheaper than natural gas.
- District Cooling: €38/MWh, 5–12% cheaper than electricity.
- Industrial clients: custom pricing (B2B model).

Case Study – Mercabarna (Ecoenergies)

- Replacing 32 GWh/year electricity with District Cooling.
- Savings:
 - 20% lower electricity costs.
 - 8,730 tCO₂ emissions avoided per year.

5.3. DCN COLD ENERGY RECOVERY FROM LIQUEFIED NATURAL GAS VAPORIZATION

Background

- Buildings consume ~40% of global energy; cooling demand is rising.
- Global residential cooling demand: 300 TWh (2000) → 4000 TWh (2050) → 10,000 TWh (2100).
- Cooling demand is harder to predict than heating, affected by solar radiation, internal gains, and urban heat islands.

District Cooling Systems (DCSs)

- Centralized cooling solution for multiple buildings.
- Components: Generation unit, distribution network, customers, heat rejection system.
- Recognized as Best Available Technology (BAT) in the EU.

Waste Cold Energy from LNG


- LNG regasification releases significant cold energy (~1245 MWh/year in Italy from L–CNG stations).
- Potential for free cooling, reducing electricity demand in air conditioning.
- No prior studies on coupling DCSs with L–CNG cold energy recovery.

5.3. DCN COLD ENERGY RECOVERY FROM LIQUEFIED NATURAL GAS VAPORIZATION

Case study


Cold Energy Potential

- Annual LNG consumption in L-CNG stations: 5400 t/year
- Cold energy wasted during regasification: 830 kJ/kg LNG
- Recoverable cold energy:
 - ~380 kWh/day (if operating 365 days/year)
 - ~550 kWh/day (if excluding weekends, 253 days/year)



Cooling Power Profiles

- P1: Constant supply (10 h/day, 365 days/year)
- P2: Constant supply (excluding weekends & lunch breaks)
- P3: Variable profile with peak at 6–7 p.m.



5.3. DCN COLD ENERGY RECOVERY FROM LIQUEFIED NATURAL GAS VAPORIZATION

Simulation Results

Reference Case

- Separate cooling systems: Fan coil units powered by a heat pump
- Cooling demand (July–August): 47 MWht
- Electricity consumption: 17 MWhe

Free Cooling Power Analysis



- DCS directly connected to the heat exchanger (no TES):
- P1 (constant supply): 50% cooling demand covered, 52% electricity savings
- P2 (weekday adjustment): 58% electricity savings
- P3 (variable supply): Less efficient due to demand-supply mismatch

Thermal Energy Storage (TES) Impact

- 60 m³ tank introduction:
- P3 case: 59% cooling demand covered, 60% electricity savings
- P1 & P2 cases: Minimal impact due to regular supply
- Enables better demand-supply balance

TES Sizing Considerations

- Optimal range: 30–90 m³
- Smaller tanks: Insufficient thermal inertia
- Larger tanks: Increased heat losses & slower system response



5.3. DCN COLD ENERGY RECOVERY FROM LIQUEFIED NATURAL GAS VAPORIZATION

Conclusions

- **DCS Benefits:**
 - Low-cost cold energy supply with reduced CO₂ emissions
 - Integration with renewables, trigeneration, and thermal storage
 - Efficient waste cold energy recovery (ex, L–CNG refueling stations)
- **Case Study:**
 - System: L–CNG refueling station supplying cooling to a residential neighborhood
 - Best Performance: 60% electricity savings (P3 profile + 60 m³ TES)
 - General Savings: >50% electricity reduction across all scenarios
- **Considerations & Future Work:**
 - Results depend on assumptions about LNG vaporizer energy availability
 - Further studies needed on DCS sizing and user connection optimization
- **Main conclusions:**
 - LNG vaporization can effectively supply residential DCSs
 - Integrating transport and residential cooling enhances urban sustainability

5.4. CONCLUSIONS

Key success factors (external)	Description
Adequate national policy and regulatory environment	The national energy policy and regulatory environment provide adequate ground and incentives for the development of DHC systems
Direct/indirect financial support	DHC projects benefit from existing direct/indirect subsidies
Focused local policy and coherence with urban planning	Local authorities promote DHC as part of their energy supply and climate strategy and integrate heat planning in their urban development projects
Alignment of interests / Cooperation maturity	Public authorities at national and local level, regulating bodies, end users, the DHC company and other local actors cooperate in an efficient manner to achieve a good quality service and a sustainable and cost-efficient heat and cold supply



Thank you!

Module 4 - District Cooling
SHaKE – Sharing Heat and Knowledge on Energy Communities

<https://www.shakeproject-dhc.eu/>

Developed by UJI
Dr. Adrián Mota-Babiloni | mota@uji.es
Ghad Alarnaot-Alarnaout | alarnaot@uji.es



Co-funded by
the European Union

